



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

Laboratory Report

Town of Chester
84 Chester St, Attn: Maintenance
Chester, NH 03036

Date Printed: 08/09/2022
Work Order #: 2208-01615
Client Job #:
Date Received: 08/08/2022
Sample collected in: New Hampshire

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

Nashoba Analytical:
Identified by MA in the Analyst Column
31A Willow Road, Ayer, MA 01432
www.nashobaanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.



Donald A. D'Anjou, Ph. D.
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507
Nashoba Analytical: Accreditations: Massachusetts M-MA1118



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

CERTIFICATE OF ANALYSIS FOR RECREATIONAL WATER

Legend

DATE PRINTED: 08/09/2022
CLIENT NAME: Town of Chester
CLIENT ADDRESS: 84 Chester St, Attn: Maintenance
Chester, NH 03036

Passes
Fails EPA Primary
Fails EPA Secondary
Fails State Guideline
Attention

SAMPLE ID #: 2208-01615-001
SAMPLED BY: Domingues, Nathan
by GSA QCM App. I
SAMPLE LOCATION: Wason Pond Beach
Chester NH

DATE AND TIME COLLECTED: 08/08/2022 09:38AM
DATE AND TIME RECEIVED: 08/08/2022 09:55AM
ANALYSIS PACKAGE: MPN-Beach
RECEIPT TEMPERATURE: ON ICE 27.6° CELSIUS
CLIENT JOB #:

MORE LOC INFO:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
E. coli MPN	95.9	MPN/100mL			1	88	SM 9223B	SM-NH	08/09/2022 10:42AM
Total Coliform / E.coli Bacteria Preparation (Colilert®-18 Quanti-Tray®) 20th ED SM 9223B RS-NH 08/08/2022 02:57PM									



Donald A. D'Anjou, Ph. D.
Laboratory Director